

BUILDING INSPECTION NOTICE

B-Complete; E-Complete; M-Complete; P-Complete

Permit #: 1 9 - 1 2 4 9 9 6 - R S

LI:

Supervisor Tel: 408 535-6873

Confirmation #: 0 1 8 2 7 5 3 0

Received: 07/23/2019

By: Phone

Preferred: PM

Scheduled: 07 / 26 / 19

Tract: 571

Lot: 10

of Units:0 Map: 833 E 6

Address: **2351 NEWHALL ST SAN JOSE**

Contact: **SERGIO**

Phone: (408) 702-0807

ETA Call: Y

Owner: NAISH ROBERT R AND SUSANN M

Home: (408)243-3813

Contractor: LEMON REMODELING

Work: (408)883-0191

Folder Name: (BEPM 100%)ALTERATION

Subtype: Single Family

Work Proposed: Additions/Alterations

Comments: PGE IS COMING IN AM CAN HE HAVE A AFTERNOON APOINTMENT

Related Permits:

Insp Time: 1 : 00

Inspection time listed at the left includes 10 minutes travel time.

Next Inspections Suggested

Number of Units:

Time inspection completed

[illegible]

Remarks: 9 11 OK

2/0 Cu SR SEC, #4 Solid Cu GEC, 2 Ground Rods
Intersystem bonding termination installed.

You have a total of 0.16 hour(s) remaining on this project as of Thursday, July 25, 2019 1:39:08 PM.

Inspector's Signature:

Print:

Date: 07 / 26 / 19

Page: 1 of 1

City of San Jose Inspection Request Voice: (408) 535-3555 Please Retain For Your Records

Field Copy